



Ref. Certif. No.

SE-115665

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Rechargeable Li-ion battery system

Name and address of the applicant

Dyness Digital Energy Technology Co., LTD.
Building 5, 688 Liupu Road, Wuzhong District, Suzhou City,
215100 Jiangsu, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Daqin New Energy Technology (Taizhou) Co., Ltd.
No.511 Chenzhuang West Road, Sanshui Street, Jiangyan
District, Taizhou City, Jiangsu Province, China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)

DYNESS

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 63056:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2407B2388SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 17 January, 2025

intertek

Signature:

Hyden Li 



Ref. Certif. No.

SE-115665

Model / Type Ref.

STACK100-3S, STACK100-4S, STACK100-5S, STACK100-6S, STACK100-7S, STACK100-8S, STACK100-9S, STACK100-10S, STACK100-11S, STACK100-12S, STACK100-13S, STACK100-14S, STACK100-15S

Ratings and principal characteristics

STACK100-3S: 153.6V, 100Ah;
STACK100-4S: 204.9V, 100Ah;
STACK100-5S: 256.0V, 100Ah;
STACK100-6S: 307.2V, 100Ah;
STACK100-7S: 358.4V, 100Ah;
STACK100-8S: 409.6V, 100Ah;
STACK100-9S: 460.8V, 100Ah;
STACK100-10S: 512.0V, 100Ah;
STACK100-11S: 563.2V, 100Ah;
STACK100-12S: 614.4V, 100Ah;
STACK100-13S: 665.6V, 100Ah;
STACK100-14S: 716.8V, 100Ah;
STACK100-15S: 768.0V, 100Ah

Date: 17 January, 2025

Signature: